



GOVERNMENT OF THE DISTRICT OF COLUMBIA

Department of Energy & Environment

Toxic Substances Division

Underground Storage Tank Branch

Public Record - Summary Information

On Motor Fuel Underground Storage Tanks (USTs)

Public Record Posted Date : 10/19/2021

General Information

Total Number of Active or Temporarily Closed Federal UST Facilities	236
Total Number of Temporarily Closed Federal UST Facilities	6
Total Number of Active or Temporarily Closed Federal UST tanks	532
Total Number of Temporarily Closed Federal UST tanks	18
Total Number of Active and Inactive Federal Leaking UST (LUST) Cases	1032
Total Number of Active Federal LUST Cases	114
Total Number of Closed Federal LUST Cases	918

Summary Information for On-Site Inspections

Number of UST Facilities Inspected	68
Inspection Period Dates:	10/1/2020 to: 9/30/2021
Release Prevention Compliant:	94%
Release Detection Compliant:	94%
Percent Compliance (Combined Measure):	91%

Note: Tank, facility, and on-site inspection information is based on inspection of UST motor fuel facilities only; heating oil USTs are not included. On-site inspections measure compliance with U.S. EPA regulations governing the prevention and detection of petroleum releases or discharging from

Summary Information for Releases

Number of Confirmed UST Releases:.....	17
Release Reporting Period Dates:	10/1/2020 to: 9/30/2021

Summary Information for Release Sources and Causes - New Federal LUST Cases

Source	Cause															
	Corrosion		Install		Other		Overfill		Phys/Mech		Spill		Unknown		Totals	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Delivery	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Dispenser	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Other	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Piping	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
STP	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Tank	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	3	18%	3	18%
Unknown	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	14	82%	14	82%
Totals	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	17	100%	17	100%

= number % = percent of releases by source or percent of causes by source
 Other (Source) low level contamination, not expected to be a continuing release from a UST system
 Other (Release) cause is known but does not fit into other categories

To obtain site specific information please visit our website <http://doee.dc.gov/node/11732> , submit a FOIA application at <http://doee.dc.gov/page/open-government-and-foia-doe> or contact us at Department of Energy & Environment, Underground Storage Tank Branch, Tel: 202-299-3322, Fax: 202-535-1383, E-mail: ust.doe@dc.gov.