



# GOVERNMENT OF THE DISTRICT OF COLUMBIA

## Department of Energy & Environment

### Toxic Substances Division

### Underground Storage Tank Branch

## Public Record - Summary Information On Motor Fuel Underground Storage Tanks (USTs)

Public Record Posted Date : 11/30/2023

### General Information

Total Number of Active or Temporarily Closed Federal UST Facilities	232
Total Number of Temporarily Closed Federal UST Facilities	5
Total Number of Active or Temporarily Closed Federal UST tanks	523
Total Number of Temporarily Closed Federal UST tanks	13
Total Number of Active and Inactive Federal Leaking UST (LUST) Cases	1054
Total Number of Active Federal LUST Cases	111
Total Number of Closed Federal LUST Cases	943

### Summary Information for On-Site Inspections

Inspection Period Dates	10/01/2022-09/30/2023
Number of UST Facilities Inspected	67
Spill prevention	93%
Overfill prevention	94%
Corrosion protection	96%
Release detection	94%
Technical compliance rate	85%
Operator training	99%
Financial responsibility	100%
Walkthrough requirements	94%

Note: Tank, facility, and on-site inspection information is based on inspection of UST motor fuel facilities only; heating oil USTs are not included. On-site inspections measure compliance with U.S. EPA regulations governing the prevention and detection of petroleum releases or discharging from underground storage tanks.

### Summary Information for Releases

Number of Confirmed UST Releases:.....8

Release Reporting Period Dates: 10/1/2022 to: 9/30/2023

### Summary Information for Release Sources and Causes - New Federal LUST Cases

Source	Cause															
	Corrosion		Install Problem		Other		Overfill		Phys/Mech Damage		Spill		Unknown		Totals	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Delivery	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %
Dispenser	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %
Other	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %
Piping	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %
STP	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %
Tank	1	13 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	1	13 %	2	25 %
Unknown	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	6	75 %	6	75 %
Totals	1	13 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	7	88 %	8	100 %

# = number           % = percent of releases by source or percent of causes by source  
Other (Source) low level contamination, not expected to be a continuing release from a UST system  
Other (Release) cause is known but does not fit into other categories

To obtain site specific information please visit our website <http://doee.dc.gov/node/11732> , submit a FOIA application at <http://doee.dc.gov/page/open-government-and-foia-doee> or contact us at Department of Energy & Environment, Underground Storage Tank Branch, Tel: 202-299-3322, Fax: 202-535-1383, E-mail: [ust.doee@dc.gov](mailto:ust.doee@dc.gov).